



Certificate of Compliance

This certificate is issued for the following equipment:

Open Water-Spray Nozzles for Permanently Piped Systems

Model	Nominal K-Factor (gpm/(psi) ^{1/2})	Nominal Spray Angle (Degrees)	NPT (in.)	Finishes
TF10	0.63	170	1/4	Brass ^a , Bronze, Copper Alloys

Notes: a - "Naval Brass" is not an FM Approved alloy for the TF10 nozzle

Prepared for: Bete Fog Nozzle Inc., 50 Greenfield Street, Greenfield, MA 01301, USA

Manufacturing Location: Bete Fog Nozzle Inc., 50 Greenfield Street, Greenfield, MA 01301, USA

FM Approvals Class: 2025

FM Approval Standard: Class Series 2021/2025 (February 2010)

Approval Identification: 3060448

Approval Granted: May 17, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group